



**Pei Evaluation Service** is an accredited ISO Standard 17065 Product Certifier, accredited by the IAS. This **Product Evaluation Report** represents a product that **Pei ES** has Evaluated. This product has a Product Evaluation Service Agreement & Follow-up Inspection Service Agreement. This **Product Evaluation Report** in no way implies warranty for this product or relieves **LaSalle Bristol** of their liabilities for this product. This **PER** is an official document if it is within one year of the Initial or Re-Approval date.

**Initial Approval**  
October, 2014

**Re-Approved**  
October, 2018

See all **Pei ES** Listings at: [www.p-e-i.com](http://www.p-e-i.com)

## Report Owner

**LaSalle Bristol**  
601 County Road 17  
Elkhart, IN 46515

## Product

**Go Guard** MH/Modular Synthetic Shingle Underlayment

## Approved Manufacturing Locations

**Cady Bag Company, LLC**  
41 Project Circle  
Pearson, GA 31642

## Evaluation Report Information

**LaSalle Bristol Contact:** Manuel Ponce - (574) 295-4400  
[www.lasallebristol.com](http://www.lasallebristol.com)

## General Details

**LaSalle Bristol Go Guard** MH/Modular Synthetic Shingle Underlayment is manufactured by Cady Bag Company, LLC. The manufacturing facility has an approved Quality Control Manual for manufacturing this product. **LaSalle Bristol** has a Product Evaluation Service Agreement with **Pei Evaluation Service® (Pei ES)** and a Follow-up Inspection Service Agreement with **Progressive Engineering Inc. (Pei)**. The product manufacturer is audited periodically by **Pei**.

## Product Description

**Go Guard** MH/Modular Synthetic Shingle Underlayment is a non-woven polypropylene layer laminated to a biaxial oriented polypropylene film. The approximate material thickness is .009" with a weight of 2.1 ounces per square yard.

## General Product Use

**Go Guard** MH/Modular Synthetic Shingle Underlayment is intended for use with asphalt based shingles as an alternative to ASTM D226, Type I and ASTM D4869, Type I roofing underlayment as specified in Section 905.2.3 of the 2012 IRC and Section 905.1.1 of the 2015 IRC. **Go Guard** MH/Modular Synthetic Shingle Underlayment is for use in factory built structures only. This product is **not** to be used with classified or fire rated roof assemblies or as an ice barrier. The manufacturer's installation instructions provide recommendations for product repair and cold weather applications.

## Building Code Compliance

**International Residential Code® 2009 and 2012 - Section 905.2.3 and 2015 - Section R905.1.1**

**Federal Manufactured Home Construction and Safety Standards, 24 CFR 3280.**

This Product has been Tested and Evaluated to meet ASTM D6757-07, Section 6, Table 1.

## Product Installation

**Go Guard** MH/Modular Synthetic Shingle Underlayment shall be installed following the manufacturer's installation instructions and in accordance with Section R905.2.7 of the **2012 IRC** and Section 905.1.1 of the **2015 IRC**. The manufacturer's installation instructions must be easily available to the installer.

1. The underlayment must be installed over solid sheathing as described in the **IRC**.
2. The underlayment is laid horizontally, parallel to the eave and may be installed with either side facing upward. It is recommended to install the coated side up.
3. The minimum roof slope allowed is 2:12, 17% slope.
4. Roof slopes from 2:12 up to 4:12, where the roof is covered with asphalt shingles, doubling the underlayment is required. Doubling is not required on units manufactured to the Federal Manufactured Home Construction and Safety Standards, 24 CFR 3280.
5. The minimum number of mechanical fasteners shall be used to hold the underlayment in place.
6. The shingles shall be installed immediately after the underlayment application. This product must be covered before leaving the factory for protection against sun, wind and rain. All roof areas not shingled for shipping reasons that have exposed underlayment, must be covered until the shingles are installed.

### Product Labeling

**Go Guard** MH/Modular Synthetic Shingle Underlayment must be labeled with at least the following;

1. **LaSalle Bristol** Name and Address
2. A **Pei Evaluation Service**® Evaluation Mark
3. The Product Evaluation Report number, PER-13068
4. The manufacturing traceability information

This information can be applied permanently to the material or by affixing a label to the rolls of material.

### Acceptable Evaluation Marks



Figure 1 - **Go Guard** MH/Modular Synthetic Shingle Underlayment

### Product Documentation

A Product Evaluation Service Agreement between **Pei Evaluation Service**® and **LaSalle Bristol**.

A Follow-up Inspection Service Agreement between **Progressive Engineering Inc.** and **LaSalle Bristol**.

Quality Control Manual - Dated: 1/2/2018

**LaSalle Bristol** Installation instructions - GoGuard Roof Underlayment for Manufactured Housing - Dated: 5/2017

A **Pei** test report No. 2013-1297 - Evaluation of GoGuard Shingle underlayment to ASTM D6757 Inorganic underlayment.