



Product Evaluation Report

PER-07021

This Document Published By:

Progressive Engineering Inc.

Initial Listing
September, 2007

Re-Approved
10/30/08

58640 State Road 15
Goshen, Indiana 46528

574-533-0337
www.p-e-i.com

Listed Product
SurePin® Pneumatic Fastener
Listed For
Aerosmith Fastening Systems

5621 Dividend Road
Indianapolis, IN 46241

Progressive Engineering Inc. is an accredited Testing Laboratory and Third Party Quality Control Agency. This **Product Evaluation Report** represents a product that Pei has a follow-up service agreement with. This **Product Evaluation Report** in no way implies warranty for this product or relieves **Aerosmith Fastening Systems** of their liabilities for this product. Pei is accredited to ISO Standard 17020 and 17025. This **PER** is an official document if it is within one year of the initial or renewal date.

Product Manufacturing

The SurePin® Fasteners are manufactured by independent companies. Any company manufacturing product for Aerosmith, that is intended to be listed by this PER, has an agreement in place and has been previously inspected and approved by Pei.

Listing Details

SurePin® Fasteners are pneumatically driven steel pins used to attach cement fiberboard siding direct to concrete block. The smooth portion of the shank must be embedded into the concrete at least 3/4" - 1" for good depth penetration into the concrete.

Product Description

The **SurePin® Fasteners** are manufactured from AISI 1060 steel, heat treated to a Rockwell C hardness between 52 - 55 for the core and a R45N surface hardness between 39 - 50 for the surface, have a minimum tensile strength of 65,000 psi. The pins are electro-zinc plated with a chromate rinse or are mechanically zinc plated or use a nickel alloy electro-plate.

The pins are manufactured with a nominal finished shank diameter of .145" and a nominal head dia. of .300". The SurePin® is designed with a smooth shank and a ballistic point. The pins are identified by the Aerosmith logo head stamp as shown on page 2 of this PER. The pins are collated for powered gun application.

Tested to

ASTM E488-96 Section 5.2 Standard Test Method for Strength of Anchors in Concrete and Masonry Elements.

Code Compliance

1997 Uniform Building Code

2006 International Residential Code

2003 International Residential Code

2006 International Building Code

2003 International Building Code

The SurePin® Fasteners are limited to use in resisting negative wind forces in this PER.

Fire Rated assemblies are outside of the scope of this PER.

Approved Pins

5193Z	5633Z	5383Z
5503Z	5253Z	5453Z
5573Z	5323Z	

Product Documentation


SurePin® Fastening Guidelines for Cement Fiber Board dated August,2006
 A Quality Control Manual for Aerosmith Fastening Systems Dated 9/5/2005
 A Quality Control Manual from each Approved Manufacturer
 An agreement between PER owner (Aerosmith) & each Approved Manufacturer
 A follow-up Listing & Inspection agreement between *Pei* and **Aerosmith Fastening Systems**
 A Intertek ETL SEMKO test report No. 3117855-001 - ASTM E488-96 with SurePin® Fasteners attaching Hardie Siding in concrete block, dated 3/30/07.

ICC-ES Legacy Report ER-5667 - Reissued December 1, 2002

Product Labeling

Each Box of fasteners shipped, that are covered by this PER, must have a label attached with at least the following information:

1. Aerosmith Fastening Systems name, address or website.
2. Fastener designation
3. This PER number & Pei's logo
4. The catalog number
5. A lot number & Mfg. Plant Identification/Traceability
6. A Trademark head stamp by Aerosmith as shown



.300" Dia. Head

ASTM E488-96, Section 5.2 Performance Testing on the following SurePin® Fasteners

<p>Product: Aerosmith 5323HP - 1-1/4" Smooth Galvanized Pin Max HN-120A Pneumatic Nailer</p> <p>Minimum Penetration: 3/4" - 1"</p> <p>Ultimate Load (embedded into concrete block at web center): Design Load (embedded into concrete block at web center) with 2.5 safety factor:</p>	<p><u>Ultimate Withdrawal Values</u></p> <p>1165.51 lbf 466.20 lbf</p>
<p>Product: Aerosmith 5503HP - 1-1/4" Smooth Galvanized Pin</p> <p>Minimum Penetration: 1-1/8" to 1-3/16"</p> <p>Ultimate Load (embedded into concrete block at web center): Design Load (embedded into concrete block at web center) with 2.5 safety factor:</p>	<p>1168.83 lbf 467.53 lbf</p>

SurePin® plastic collated form



Boxes of 5323P as Shipped

SurePin® in collated form



Label for 5323 HP

